

7-5  
अग्नि सेवा  
अग्नि महाराज C-25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/320

Dated 01/04/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s Balvantray Mehta Vidya Bhawan Anguridevi Shersingh Memorial Academy** (School ID-1925273) located at Block-E, G & H, Masjid Moth, Greater Kailash-II, New Delhi-110048 comprised of two interconnected Blocks Ground plus Three Upper floors & Ground plus Four upper floors was issued FSC by this department vide letter No. F6/DFS/MS/School/2022/SZ/69 dated 25/01/2022. The school premise was re-inspected by officer concern of this department on 21/03/2025 in the presence of Ms. Vandana (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **"Educational, Group-B"** (School) as above with effect from 01/04/2025 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 01/04/2025 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. Sh. S.C Bahri, (Dir-Cum-Manager), Balvantray Mehta Vidya Bhawan Anguridevi Shersingh Memorial Academy, Block-E, G & H, Masjid Moth, Greater Kailash-II, New Delhi-110048
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

(VANDANA BABERWAL)  
OFFG PRINCIPAL SECOND SHIFT  
BALVANTRAY MEHTA VIDYA BHAWAN  
ANGURIDEVI SHERSINGH MEMORIAL ACADEMY  
SCHOOL ID-1925273  
G.K.-II, NEW DELHI-110048 PHONE-43715301

GP.CAPT S.C BAHRI (RETD)  
DIRECTOR cum-MANAGER  
BALVANTRAY MEHTA VIDYA BHAWAN  
ANGURIDEVI SHERSINGH MEMORIAL ACADEMY  
G.K.-II, NEW DELHI-110048 PH NO -41084582